

PLAN REVIEW SHEET

Date: January 21, 2020

Petition #: 2019-179

Staff Contact: John Howard

Parwkood Avenue is serviced by CATS local bus route #4. There is an existing bus stop and trash receptacle in front of the subject parcel. CATS request the petitioner to install an ADA compliant bus waiting pad 60.01B within the required planting strip along Parkwood Avenue at the existing bus stop. The exact location will be determined during the land development review process.

