



To: David Pettine, CMPC

From: Ashley Botkin - Planning, Design, and Development

Date: January 27, 2020

Rezoning Petition #: 2019-181

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: www.charlottenc.gov/ld.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson (Engineering) – Petitioner is advised the 100' SWIM/PCSO Stream Buffers on the site require the inclusion of 50% of the flood fringe area as additional stream buffer. Delineation of the additional stream buffer area may be deferred to the permitting process and is not required to be shown on the rezoning plan.

Peter Grisewood (Urban Forestry) – Site must comply with the Tree Ordinance.

Jay Wilson (Erosion Control) – Stream/wetland survey required prior to submission of civil site plan to ensure accurate delineation of top-of-bank/stream buffers/creek path