



CHARLOTTE FIRE DEPARTMENT
700 North Tryon Street
Post Office Box 31097 Charlotte, N.C. 28231-1097

Plan Review Sheet

Petitioner: First Colony Land development
Petition Number: 2006-64 Revisions
Fire Plans Examiner: J. Leonard
Telephone: 704-336-3814

Review: 2
Date Received: 05/01/06
Date Reviewed: 05/02/06
Fax: 704-336-3839

E-Mail: jpleonard@ci.charlotte.nc.us

Remarks :

Minimum water supply for town home land for sale is 1500 gpm at 20 psi.

Comments by staff will be based on an initial review of conceptual and/or preliminary drawings and project information, and therefore are not to be considered as binding. Submittal of additional information, or a later more detailed evaluation of the plans, including an evaluation made by a field inspector after building permits have been issued, may result in a change in interpretation by the Department as to the application of the NC State Fire Code and Ordinances to the project.