



CHARLOTTE FIRE DEPARTMENT
700 North Tryon Street
Post Office Box 31097 Charlotte, N.C. 28231-1097

Plan Review Sheet

Petitioner: Don & Caroline Nasmith
Petition Number: 2006-119
Fire Plans Examiner: R. Turner
Telephone: 704-336-3814

Review: 1
Date Received: 4-24-07
Date Reviewed: 5-8-07
Fax: 704-336-3839

E-Mail: turner@ci.charlotte.nc.us

Remarks :

- 1. Access roads are required to be 20 ft unobstructed width and turn circle 42 ft outside and 30 ft. inside turning radius.**
- 2. Hydrant required within 750 ft. of most remote point of building as truck travels.**