



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFC: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Keith MacVean, CMPC

From: Doug Lozner / Jeff Hieronymus / Danée McGee

Date of Review: February 13, 2007 *(Revised August 16, 2007)*

Rezoning Petition #: 07-40

Existing Zoning: UR-2

Proposed Zoning: ***MUDD-O***

Location of Property: Approximately **1.77** acres located on the West side of North Cedar Street between W 5th Street and Cates Street.

Downstream Complaints: Downstream complaints consist of blockage and flooding.

Review Method(s): Review of topographic information, aerial photography, and a site visit.

Recommendations due to revisions: ***Charlotte Storm Water Services (CSWS) recommends that this petition and site plan be revised as follows:***

Storm Water Quantity Control

The petitioner shall tie-in to the existing storm water system(s). The petitioner shall have the receiving drainage system(s) analyzed to ensure that it will not be taken out of standard due to the development. If it is found that development will cause the storm drainage system(s) to be taken out of standard, the petitioner shall provide alternate methods to prevent this from occurring.

Storm Water Quality Treatment – Source: BMP recommendation taken from “Post-Construction Ordinance Stakeholders’ Group Final Report”

For projects with defined watersheds greater than 24% built-upon area, construct water quality best management practices (BMPs) to achieve 85% Total Suspended Solid (TSS) removal for the entire post-development runoff volume for the runoff generated from the first 1-inch of rainfall. BMPs must be designed and constructed in accordance with the N.C. Department of Environment and Natural Resources (NCDENR) Best Management Practices Manual, April 1999, Section 4.0 (Design Standards shall be met according to the City of Charlotte Best Management Practices Manual, when available). Use of Low Impact Development (LID) techniques is optional.

Volume and Peak Control – Source: Volume Control and Peak Control Downstream Analysis taken from “Post-Construction Ordinance Stakeholders’ Group Final Report”.

For projects with defined watersheds greater than 24% built-upon area, control the entire volume for the 1-year, 24-hour storm. Runoff volume drawdown time shall be a minimum of 24 hours, but not more than 120 hours.

For residential projects with greater than 24% BUA, control the peak to match the predevelopment runoff rates for the 10-year and 25-year, 6-hour storms or perform a downstream analysis to determine whether peak control is needed, and if so, for what level of storm frequency. "Residential" shall be defined as "A development containing dwelling units with open yards on at least two sides where land is sold with each dwelling unit."

For commercial projects with greater than 24% BUA, control the peak to match the predevelopment runoff rates for the 10-yr, 6-hr storm and perform a downstream flood analysis to determine whether additional peak control is needed and if so, for what level of storm frequency, or if a downstream analysis is not performed, control the peak for the 10-yr and 25-yr, 6-hour storms.

For commercial projects with less than or equal to 24% BUA, but greater than one acre of disturbed area, control the peak to match the predevelopment runoff rates for the 2 and 10-yr, 6-hr storm.