



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFC: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Keith MacVean, CMPC

From: Doug Lozner / Jeff Hieronymus / Danée McGee

Date of Review: March 13, 2007 *(Revised April 24, 2007)*

Rezoning Petition #: 07-66

Existing Zoning: O-1 (CD)

Proposed Zoning: NS

Location of Property: Approximately 1.73 acres located on the north side of W. Mallard Creek Church Road between David Taylor Drive and Claude Freeman Drive.

Downstream Complaints and analysis: None.

Source citation: A portion of the water quantity and quality comments reference information gained from the "Post-Construction Ordinance Stakeholders' Group Final Report". This report reflects consensus reached during the Council-approved process to include community input on the proposed ordinance language. Other comments, including the environmental permit, stream buffer and some detention requirements reflect existing regulations and ordinances.

Recommendations

Concerning Storm Water: **Charlotte Storm Water Services recommends that this petition be revised to include the following notes on the petition:**

Storm Water Quality Treatment – Source: BMP recommendation taken from "Post-Construction Ordinance Stakeholders' Group Final Report"

For projects with defined watersheds greater than 24% built-upon area, construct water quality best management practices (BMPs) to achieve 85% Total Suspended Solid (TSS) removal for the entire post-development runoff volume for the runoff generated from the first 1-inch of rainfall. BMPs must be designed and constructed in accordance with the N.C. Department of Environment and Natural Resources (NCDENR) Best Management Practices Manual, April 1999, Section 4.0 (Design Standards shall be met according to the City of Charlotte Best Management Practices Manual, when available). Use of Low Impact Development (LID) techniques is optional.

Recommendations

due to revisions: ***No additional comments are needed at this time.***