



**CHARLOTTE FIRE DEPARTMENT**  
**700 North Tryon Street**  
**Post Office Box 31097 Charlotte, N.C. 28231-1097**

**Plan Review Sheet**

**Petitioner: Meeting St. Companies**  
**Petition Number: 2007-092**  
**Fire Plans Examiner: R. Turner**  
**Telephone: 704-336-3814**

**Review: 1**  
**Date Received: 5-5-07**  
**Date Reviewed: 5-10-07**  
**Fax: 704-336-3839**

**E-Mail: [turner@ci.charlotte.nc.us](mailto:turner@ci.charlotte.nc.us)**

**Remarks :**

- 1. Access requirements will include 20 ft unobstructed, including alley ways.**
- 2. Water supply does not appear sufficient for proposed project without additional fire and life safety features.**