



CHARLOTTE FIRE DEPARTMENT
700 North Tryon Street
Post Office Box 31097 Charlotte, N.C. 28231-1097

Plan Review Sheet

Petitioner: Boulevard Centro
Petition Number: 2007-099
Fire Plans Examiner: R. Turner
Telephone: 704-336-3814

Review: 1
Date Received: 5-5-07
Date Reviewed: 5-11-07
Fax: 704-336-3839

E-Mail: turner@ci.charlotte.nc.us

Remarks :

- 1. Water supply appears insufficient for proposed project without additional fire and life safety features.**
- 2. Access requirements shall meet N.C. Fire Code chp. 5.**