



## PLAN REVIEW SHEET

---

<b>Date:</b>	5.18.09	<b>Staff Contact:</b>	David McDonald
<b>Petitioner:</b>	Winter Elizabeth	<b>Telephone:</b>	704-336-6900
<b>Petition:</b>	2009-048	<b>Fax:</b>	704-432-1277
		<b>Email:</b>	<a href="mailto:dmcdonald@ci.charlotte.nc.us">dmcdonald@ci.charlotte.nc.us</a>
		<b>Attachments:</b>	Standard 60.02A and Petitioner's site plan

---

### I. SUMMARY REMARKS:

#### FIRST SUBMITTAL

CATS requests that Petitioner provide two (2) concrete waiting pads along East 7<sup>th</sup> Street at CATS' existing bus stops. The standard for the pad is 60.02A and is attached hereto. A site plan showing the approximate location of the existing stops is also attached hereto. However, please contact William (Budd) Early of CATS Facilities Management staff at 704.432.2557 regarding the final location of the pads and for any questions related to this request. Thank you.

**Should you require additional information, please advise.**