



September 16, 2009

Attention: Michael Cataldo
Petition #: 2009-071

Proximity to CMUD Water: Existing 6" Water Main accessible South of site on South side of Ardsley Road, Existing 2" Water Main accessible North East of site on the North East side of Hermitage Road.

Proximity to CMUD Sewer: Existing 8" Sewer located North of site along Edgehill Road South, Existing 8" Sewer located South of site along Ardsley Road.