



October 12, 2009

Attention: Michael Cataldo  
Petition #: 2009-080

Proximity to CMUD Water: Existing 12" Water Main accessible West of site along North Community House Road. Existing 16" Water Main accessible South of site along Ballantyne Commons Parkway.

Proximity to CMUD Sewer: Existing 10" Sewer located within the East side of the site paralleling the creek.