

November 30, 2009

Attention: Michael Cataldo

Petition #: 2010-014

## Proximity to CMUD Water:

Existing 8" Water Main is accessible northeast of the Site along E. Fifth Street. Existing 12" Water Main is accessible southeast of the Site along North College

Street.

## Proximity to CMUD Sewer:

Existing 8" Sewer is accessible northeast of Site along E. Fifth Street. Existing 8" Sewer is accessible southeast of Site along North College Street.