



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFC: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Tammie Keplinger, CMPC

From: Matthew Anderson/Doug Lozner

Date of Review: May 17, 2011 **(Revised June 21, 2011)**

Rezoning Petition #: 11-044

Existing Zoning: R-3 & BP(CD)

Proposed Zoning: BP(CD), BP(CD) SPA & O-3(CD)

Location of Property: Approximately 520 acres generally bounded by Interstate 485 to the north, Ballantyne Commons Parkway to the south, and Rushmore Street and North Community House Road to the west and east, respectively.

Recommendations

Concerning Storm Water: **Please add the following notes:**

For initial development of undeveloped land within the boundaries of the petition, the Post Construction Controls Ordinance (PCCO) shall not apply if storm water runoff from the proposed built-upon-area drains to an existing bmp which has been demonstrated to have been previously master planned, designed and constructed to treat storm water runoff from the proposed built-upon-area. For initial development not meeting these criteria, PCCO compliance will be required.

All redevelopment shall be subject to the PCCO (see PCCO for definition of "redevelopment").