



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2013-101	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	October 11, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

8-inch water main on Bellhaven Boulevard and 12-inch water main on Valleydale Road.

8-inch gravity sewer on Valleydale Road and Bellhaven Boulevard.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.