



**Charlotte Mecklenburg Utility Department**  
**5100 Brookshire Boulevard**  
**Charlotte, NC 28062**  
Re-Zoning Petition Review

<b>Petition #:</b>	2013-102	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	October 11, 2013
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

8-inch water main on East 34<sup>th</sup> street and 6-inch water main on North Davidson Street.

8-inch gravity sewer mains on North Davidson Street and East 34<sup>th</sup> Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.