



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-049	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	April 16, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 12-inch and 8-inch water mains along Morrison Boulevard.

Access to the CMUD Sewer Service is available from the existing gravity sewer mains that run through parking lot of parcel under review. The proposed project plans included in the rezoning application show the proposed construction in the same location of existing sewer main. The developer will need to work with CMUD to plan and design the relocation of the infrastructure.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.