



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-059	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	May 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 24-inch and 8-inch water mains along Sharon Road.

Access to the CMUD Sewer Service is available via the existing 24-inch gravity sewer main that runs along Sharon Road, and an existing 8-inch gravity sewer main along the north side of parcel under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.