



**Charlotte Mecklenburg Utility Department**  
**5100 Brookshire Boulevard**  
**Charlotte, NC 28062**  
Re-Zoning Petition Review

<b>Petition #:</b>	2014-076	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	July 10, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 12-inch water main along Reames Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains located along Reames Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.