



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

| | | | |
|---------------------------|--------------|-----------------------|--------------------------|
| Petition #: | 2014-101 | Review Number: | 1 |
| Petition Reviewer: | Matt Bedford | Date Reviewed: | September 25, 2014 |
| Phone Number: | 704-391-5163 | Email Address: | mbedford@charlottenc.gov |

Comments:

Access to the CMUD Water System is available via the existing 12-inch water main along Reames Road.

Access to the CMUD Sewer Service is available from two existing 8-inch gravity sewer mains along Reames Road. Both of these connection points are approximately 500 feet from the parcels under review. Developers will need to work with CMUD's IDS group to provide connection to the sewer system.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.