



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-105	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	September 25, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 2-inch water mains along Leawood Lane and Grayling Court.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains along Grayling Court, Leawood Lane, as well as an 8-inch gravity sewer main that connects these two lines, and heads south, towards McAlpine Creek. Access is also available from the existing 18-inch gravity sewer main running along McAlpine Creek.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.