



**Charlotte Mecklenburg Utility Department**  
**5100 Brookshire Boulevard**  
**Charlotte, NC 28062**  
Re-Zoning Petition Review

<b>Petition #:</b>	2014-106	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	September 25, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 48-inch and 12-inch water mains along Park Road, and the existing 8-inch water main along Gleneagles Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains connection located to at the North East corner of the property under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.