



**Charlotte Mecklenburg Utility Department**  
**5100 Brookshire Boulevard**  
**Charlotte, NC 28062**  
 Re-Zoning Petition Review

<b>Petition #:</b>	2015-005	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	November 25, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 12-inch and 8-inch water mains along Choate Circle.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains along Choate Circle, as wells as the existing 24-inch, 30-inch, and 42-inch gravity sewer mains currently located within the parcels under review. If any development on these parcels will affect these existing sewer mains, the developer will need to work with CMUD’s Installation and Development Services group to plan accordingly.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.