



Petition #:	2015-111	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	August 26, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water does not currently have water system availability. The closest water system availability is approximately 230 feet from the northeast corner of parcel 157-073-15 along North Wendover Road. The developer should contact Charlotte Water's Installation & Development Services for information regarding development around water services for these parcels.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located on the eastern and southern border of the parcels and along North Wendover Rd to the northwest.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.