



Petition #:	2015-113	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	August 26, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 8-inch water main located along South Tryon Street.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located along South Tryon Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.

