

Petition #:	2015-122	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	October 6, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 8-inch water main located along North Community House Road and the 6-inch water main located along Paradise Ridge Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along North Community House Road and Paradise Ridge Road. It should be noted that the sewer availability along North Community House Road is only accessible to parcels 223-375-02 and 233-372-03.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.