

Petition #:	2015-131	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	October 6, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 8-inch water mains located near the northern corner of the Development Area A and near the eastern corner of Development Area B (as shown on Technical Data Sheet RZ-1). The associated intersections are Sharon Road/Colony Road and Roxborough Road/Colony Road.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along the border of Development Area A on Colony Road, along Development Area C on Roxborough Road, and bordering the southwest portion of the property (Development Areas C & D).

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.