

Petition #:	2016-002	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	November 13, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along South Bruns Avenue and Duckworth Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along South Bruns Avenue, Duckworth Avenue, and West Trade Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.