



2016-005
Up to 280 multifamily units

Attn: Zenia Duhaney
Reviewer: Mavis Gant

Date: November 3, 2015

Comments: Garbage/Recycling collection plans are not indicated. This property needs to have a trash chute that goes into a self-contained compactor and not use a trash chute with the 2cy or 4cy roll out dumpsters for collection as there is no safe place or enough room to place the number of roll out dumpsters needed for a community of this size. There also needs to be a place to roll out recycling containers and place bulky items for collection.

If the property chooses not to have a self-contained compactor, a curb cut will need to be approved to provide a garbage truck access to roll each individual dumpster in front of the garbage truck to empty and roll back onto the sidewalk.

Other comments: If there are any questions, please contact Solid Waste Administration, 704-432-3537.