

To: Tammie Keplinger, CMPC

From: Ashley Botkin, Engineering Land Development

Date: March 29, 2016

Rezoning Petition #: 2016-017 Revised

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division after land entitlement (approved rezoning). Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: http://development.charmeck.org.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson – No comments

Laurie Dukes – Trees greater than two (2) inches diameter as measured 4.5' above ground and in the street right of way are protected by law; authorization for their removal is to be coordinated through the City Arborist office. Development of the site shall comply with the requirements of the City of Charlotte Tree Ordinance. The portion of the property located in the Wedge must provide trees save on site. Tree save area to be minimum 30 feet wide; no buildings within ten (10) feet of tree save; no grading in the tree save area.

Jay Wilson -