

Petition #:	2016-030	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	December 16, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Park Road and Mockingbird Lane.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located along Park Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.

Charlotte Water 5100 Brookshire Blvd, Charlotte, NC 28216 charlottewater.org