



<b>Petition #:</b>	2016-039	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	January 13, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

Charlotte Water currently does not have water system availability for the parcel under review. The closest available water main is approximately 200 feet west of the property at the intersection of South Tryon Street and Wright's Ferry Road. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to the water system.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located within the property near the north corner of the parcel.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.