



Petition #:	2016-054	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	February 19, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water currently has water system availability via an existing 12-inch water main located along Eastway Drive and an existing 8-inch water main located along Shamrock Drive.

In relation to the parcels under review, Charlotte Water currently has sewer system availability via existing 10- and 15-inch sewer mains located within the western and southern portions of the property boundary and existing 10-inch sewer mains located along Shamrock Drive and Eastway Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.