

MECKLENBURG COUNTY

Land Use and Environmental Services Agency

March 24, 2016

Ms. Zenia Duhaney Charlotte-Mecklenburg Planning Commission 600 East Fourth Street Charlotte, North Carolina 28202

Re: Rezoning Petition 2016-069

Location: 0.83 acres at the intersection of N. Caldwell St and Belmont Ave on the south quadrant

Dear Ms. Duhaney:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

Programs with No Comment at this Time

Solid Waste, Water Quality, Air Quality

Recommendations and/or Ordinance Requirement Reminders

Groundwater & Wastewater Services

GWS records indicate a contamination site(s) exist on or within 1,500 feet of the properties included in the petitions. An established Area of Regulated Groundwater Usage (ARGU) as defined by the Mecklenburg County Groundwater Well Regulations extends 1,500 feet around the contamination sites. In ARGU where municipally supplied water is available water supply wells for water supply, irrigation or open loop geothermal systems may not be permitted or constructed on or within 1,000 feet of contamination sites. Wells may be permitted with special construction and sampling requirements between 1,000 and 1,500 feet of contamination sites.

No further comments on the above petition at this time.

Please contact the staff members who conducted the reviews if you have any questions. The reviews were conducted by, Megan Green (Megan.Green@mecklenburgcountync.gov) with MCAQ, Dennis Tyndall

Page 2

(Dennis.Tyndall@mecklenburgcountync.gov) with GWS, Joe Hack (Joe.Hack@mecklenburgcountync.gov) with MCSW, and Rusty Rozzelle (Rusty.Rozzelle@mecklenburgcountync.gov) with MCWQ.

Respectfully,

Jeanne Quinn, Administrative Support Supervisor Jeanne.quinn@mecklenburgcountync.gov