



Petition #:	2016-070	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 18, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

Charlotte Water does not currently have water system availability for the parcels under review. The closest water distribution main is located approximately 350 feet southeast of the eastern corner of the property on Northlake Centre Parkway.

In relation to the parcels under review, Charlotte Water currently has sewer system availability via an existing 8-inch sewer main located along East I-485 Inner Highway and within the boundaries of parcel 025-105-09.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.