



Petition #:	2016-074	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	April 6, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 36-inch water main located along North Tryon Street. There is also system availability for the rezoning boundary through existing 12-inch and 8-inch water distribution mains.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer mains located along West Rocky River Road and an existing 8-inch gravity sewer main located in the southern portion of parcel 049-18-104.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.