



Petition #:	2016-079	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	April 6, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via existing 6-inch and 12-inch water distribution mains located along East Craighead Road and an existing 2-inch water distribution main located along Philemon Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along East Craighead Road and Philemon Avenue. There is also a 24-inch sewer main located along the northern portion of the petition area and a 15-inch gravity sewer main located in the southwest portion of the petition area.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.