



<b>Petition #:</b>	2016-083	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	April 6, 2016
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along Harris Cove Drive and an existing 12-inch water main located along David Cox Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along David Cox Road, just south of parcel 027-21-104. There is also an existing 8-inch gravity sewer main located along Harris Cove Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.