

Rezoning Transportation Analysis

Petition Number: 2016-112

General Location Identifier: 07111401, 07111402, 07111403...

From: Kelsie Anderson, PE
Kelsie.Anderson@charlottenc.gov
 704-432-5492

Staff Reviewer: Carlos Alzate
 calzate@charlottenc.gov
 704-432-0672

CDOT's review of this rezoning petition is intended to ensure consistency with the Transportation Action Plan (TAP) which seeks to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

To be provided prior to public hearing.

General Description

State Street and Turner Avenue are two-lane minor collectors with limited sidewalks. The nearest thoroughfares are Tuckaseegee Road (major) to the south and Rozzelles Ferry Road (minor) to the north. Turner Avenue is a signed bike route that connects to the existing bike lanes on Rozzelles Ferry Road.

Site is located in a wedge inside of Route 4.

Site is within Westside Strategic Area Plan and West Trade / Rozzelles Ferry Area Comprehensive Neighborhood Improvement Program (CNIP).

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Industrial Mix	30 acres	Unknown	Petition
Entitlement with Current Zoning	Industrial Mix (30 acres of I-2)	450k sf (Office)	4,120	General Guidance from Planning
Proposed Zoning	Retail/Office/Residential Mix (30 acres of MUDD)	Too many uses to determine trip generation		General Guidance from Planning
	Retail Condo/Townhomes Apartments Hotel	100k sf 800 dwellings 1000 dwellings 100 rooms	17,720	Site Plan: 8-22-16

Rezoning Transportation Analysis

Petition Number: 2016-112

General Location Identifier: 07111401, 07111402, 07111403...

Curbline

The proposed zoning district has a setback measured from an existing or proposed future curbline. The location of the future curbline will be determined prior to public hearing.

Resolved Issues

N/A

Outstanding Issues

1. Based on the proposed land uses, a traffic impact study (TIS) is required. Contact CDOT staff reviewer for scoping. In particular, CDOT will be looking to define
 - a. Right of way reservation and/or implementation of envisioned streetscape and parallel greenway projects
 - b. Impact of and mitigation for additional vehicle trips generated by this site that may disturb the shared-use/multimodal character of the surrounding local streets (e.g. Turner Avenue, a signed bicycle route) thereby removing existing bicycle connectivity.
 - c. Turn lane and pedestrian crossing improvements at study intersections that lead directly to the site. It is anticipated that the current configuration of Turner Avenue at Rozzelles Ferry Road and at State Street are likely not adequate to support the development intensity of the proposed district.
2. The petitioner should revise the site plan to add "upon CDOT approval" to the end of transportation note (b) 3.
3. CDOT does not agree with a blanket deviation from MUDD-O streetscape provisions for existing structures (MUDD-O optional provisions note (a)) but can commit to considered case-by-case requests during the permitting phase. Without specific commitment to MUDD streetscape requirements along existing streets, reuse of existing buildings can preclude identified and committed streetscape projects.
4. The petitioner should revise the site plan to show the extension of Chamberlain Av to Stewart Av.
5. The petitioner should revise the site plan to show the extension of Stewart Av to Chamberlain Av.
6. The petitioner should revise the site plan to reserve right of way and incorporate cross section features as appropriate for West Trade / Rozzelles Ferry Area Comprehensive Neighborhood Improvement Program (CNIP) identified projects adjacent to or within the site.

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.

Rezoning Transportation Analysis

Petition Number: 2016-112

General Location Identifier: 07111401, 07111402, 07111403...

3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

Revision Log

Date	Description	By
07-18-16	First Review	CA