



| | | | |
|---------------------------|----------------|-----------------------|----------------------------|
| Petition #: | 2016-117 | Review Number: | 1 |
| Petition Reviewer: | Alan H. Gaines | Date Reviewed: | July 6, 2016 |
| Phone Number: | 704-391-4689 | Email Address: | againes@ci.charlotte.nc.us |

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along North Tryon Street.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main along University Executive Park Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.