



Petition #:	2016-146	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	October 6, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along West Tremont Avenue.

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along West Tremont Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.