

Petition #:	2017-027	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	December 6, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water does have water availability to the rezoning boundary via existing 8-inch water distribution mains located along Newland Road and Double Oak Road. There is also an existing 12-inch water distribution main located along Statesville Avenue.

In relation to the parcels under review, Charlotte Water does have sewer availability to the rezoning boundary existing 8-inch gravity sewer main located along Newland Road, Double Oak Road, Statesville Avenue, and within parcel 07511308.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.