



<b>Petition #:</b>	2017-071	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	April 19, 2017
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along East 36<sup>th</sup> Street.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along East 36<sup>th</sup> Street and the Northeast boundary for parcel 091-09-102.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.