

Petition #:	2017-093	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	6/13/2017
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 10-inch water transmission main located within the rezoning boundary.

Charlotte Water currently does not have sewer system availability for the parcel under review. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to sewer system connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.