

Petition #:	2017-172	Review Number:	1
Petition Respondent:	Keri Cantrell	Date Reviewed:	11/20/2017
Phone Number:	704-391-5141	Email Address:	keri.cantrell@charlottenc.gov

Comments:

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 6-inch water distribution main located along Harrill Street and 8-inch water distribution main along Belmont Avenue.

Charlotte Water has sanitary sewer system infrastructure accessible for the rezoning boundary via existing 8-inch gravity sewer main located along Harrill Street and Belmont Avenue.

Development is encouraged to contact Installation Development Services (IDS) at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Will need to acquire Capacity Assurance prior to granting a service tap request; development needs to contact CLTWater's New Services Group at (704) 432-5801 for information regarding meters/laterals/abandonments; and development will need to verify that there is at least 36" min cover over CLTWater's existing water main at the proposed connection at Harrill and Belmont. Documentation can be submitted to IDS.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-5801 for further information on reserving capacity up to 12 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.