



To: Tammie Keplinger, CMPC

From: Ashley Botkin, Engineering Land Development

Date: April 23, 2018

Rezoning Petition #: 2018-044

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson (Engineering) – Please revise Note-G1 under the ENVIRONMENTAL FEATURES heading to read exactly as follows: *The petitioner shall comply with the Charlotte City Council approved and adopted Post Construction Stormwater Ordinance.*

Please add the following notes under the ENVIRONMENTAL FEATURES heading: *The location, size, and type of storm water management systems depicted on the Rezoning Plan are subject to review and approval as part of the full development plan submittal and are not implicitly approved with this rezoning. Adjustments may be necessary in order to accommodate actual storm water treatment requirements and natural site discharge points.*

The Petitioner shall analyze the adequacy of the existing stormwater conveyance across any parcels receiving stormwater discharge from the site. The limits of analysis shall extend to the nearest downstream public street right-of-way. If the existing stormwater conveyance on the specified off-site parcels is found to be inadequate, the Petitioner shall make a good faith effort with the property owner(s) to improve the stormwater conveyance or otherwise mitigate the stormwater discharge onto the parcel(s).

Peter Grisewood (Urban Forestry) – Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 7.5 acres = 1.125 acres tree save. Show tree save area and calculations on site map. Tree save must contain existing healthy tree canopy. Tree save must be 30' width minimum.

Jay Wilson (Erosion Control) – No comments