

Acela Number	Luesa Number
2018-048	No comments
2018-049	No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-050	No comments
2018-051	Dead end fire apparatus access exceeding 150' requires an approved turn around minimum 20' width. Turn radius 30' inside and 42' outside.
2018-052	No comments
2018-053	No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-054	Maintain 20' unobstructed access road width at all times for CFD. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-055	Maintain 20' unobstructed access road width at all times for CFD. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-056	Maintain 20' unobstructed access road width at all times for CFD. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-057	Maintain 20' unobstructed access road width at all times for CFD. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-058	No comments
2018-059	Maintain 20' unobstructed access road width at all times for CFD. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-060	No comments
2018-061	No comments
2018-062	No comments
2018-063	No comments. Zoning Text Amendment