

Acela Number	Luesa Number
2019-001	Fire hydrant within 750' of most remote point of bldg as truck travels. Install gate per Appendix D section 503.6. See charlottefire.org for other reqmts.
2019-001(c)	Fire hydrant within 750' of most remote point of bldg as truck travels. In parking lot and all driveway loops maintain continuous 24' width for CFD access.
2019-002	Incomplete submittal
2019-003	Incomplete submittal
2019-004	Incomplete submittal
2019-005	Fire hydrant within 750' of most remote point of bldg as truck travels. No parking on road less than 26' clear width.
2019-006	No comments
2019-007	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-008	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-009	Fire hydrant within 750' of most remote point of bldg as truck travels. Dead end access exceeding 150' requires turnaround minimum 20 width with turn radius 30
2019-010	Incomplete submittal
2019-011	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-012	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-013	No comments
2019-014	Fire hydrant within 750' of most remote point of bldg as truck travels. Access road shall be 150' of nonsprinkled bldg; 200' of sprinklered bldg
2019-015	Incomplete submittal
2019-016	Fire hydrant within 750' of most remote point of bldg as truck travels. No parking on road less than 26' clear width.