



Charlotte Storm Water  
600 East Fourth Street  
Charlotte, N C 28202-2844  
OFFC: 704 . 336 . RAIN  
FAX: 704 . 336 . 6586

## *Rezoning Petition Review*

---

**To:** Charlotte Planning, Design & Development

**From:** Doug Lozner

**Date of Review:** May 17, 2019 (***Revised June 13, 2019***)

**Rezoning Petition #:** 19-57

**Existing Zoning:** I-1

**Proposed Zoning:** I-2

**Location of Property:** Approximately 9.85 acres located on the west side of Statesville Ave, north of Atando Ave and east of I-77.

**Site Plan Submitted:** **Yes**

***Recommendations***

***Due to revisions (6/13/19):*** The proposed rezoning plan sheet indicates a proposed location for storm water management. Please include the following notes on the plan sheet under "Environmental Features": *The location, size, and type of storm water management systems depicted on the Rezoning Plan are subject to review and approval as part of the full development plan submittal and are not implicitly approved with this rezoning. Adjustments may be necessary in order to accommodate actual storm water treatment requirements and natural site discharge points.*