

2019-073.....Fire hydrant within 750' of most remote point of bldg as fire truck travels. All CFD access shall be minimum 20' width curb to curb. Access road shall be within 150' of nonsprinkled building and 200' of sprinkled building. See charlottefire.org for other requirements.

2018-160.....No change from previous comments

2019-027.....No change from previous comments

2019-049.....No change from previous comments