

# Rezoning Transportation Analysis

Petition Number: 2019-158

General Location Identifier: 17101157, 17101156, 17101155

**From:** Felix Obregon, PE  
[fobregon@charlottenc.gov](mailto:fobregon@charlottenc.gov)  
704-432-5729

**Reviewer:** Carlos Alzate, PE  
[calzate@charlottenc.gov](mailto:calzate@charlottenc.gov)  
704-432-0672

## Revision Log:

Date	Description
12/18/19	First Review

## General Review Information

The site is on Woodlawn Road (major thoroughfare, state maintained) and is in a wedge outside Route 4. The site is within the limits of the Woodlawn Transit Station Area Plan.

## Active Projects Near the Site:

- No projects near site

---

*CDOT's review of this rezoning petition is intended to ensure consistency with the Transportation Action Plan (TAP) which seeks to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.*

*This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.*

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The site is located on a major thoroughfare. The petitioner should revise the site plan to meet the ordinance requirements and the outstanding items listed below.

## Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Single Family	3 dwellings	30	Tax Record
Entitlement with Current Zoning	Single Family (3.6 ac of R-4)	14 dwellings	130	General Guidance from Planning
Proposed Zoning	Townhomes	39 dwellings	250	Site Plan: 10-17-19

## Outstanding Issues

~~Strikeout~~ = Not an outstanding issue

- Curbline** The proposed zoning district has a setback measured from back of the existing or proposed future curbline.
  - Woodlawn Road:** The future location of back of curb and gutter is 38 feet from centerline of the road.

The site plan should show the curb and gutter labeled and dimensioned from the centerline for each road.

# Rezoning Transportation Analysis

Petition Number: 2019-158

General Location Identifier: 17101157, 17101156, 17101155

2. **Traffic Study** A Traffic Impact Study is not necessary for the complete review of this petition. If the during the permitting process the site generates more than 2500 daily trips, then a traffic study will be required.
3. The current approved 2007-005 rezoning commits to an 8-foot planting strip and 6-foot sidewalk on Woodlawn Road. The petitioner should revise the site plan and conditional note(s) to commit to constructing the 8-foot planting strip and 6-foot sidewalk on Woodlawn Road The back of sidewalk is located 52 feet from centerline of the road. The site plan should label and dimension both items from the back of curb and gutter and road centerline.
4. The petitioner should revise the site plan and conditional notes to include additional guest parking for the residents.
5. The petitioner should revise the site plan and conditional notes to includes a 6' wide sidewalk on both sides of Street 'A'.
6. ~~Resolved Sample format for comment that is resolved~~

Please provide a response to our comments with your resubmittal.

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.